



P.O. Box 92607  
Southlake, TX 76092  
www.nfsi.org  
Phone (817) 749-1700  
Email: info@nfsi.org

July 31, 2020

M. Sue Freyvogel  
Carbinite Metal Coatings  
463 Brownsdale Road, Unit 1  
Renfrew, PA 16053

Dear M. Sue Freyvogel:

On behalf of the National Floor Safety Institute, I would like to thank you for submitting your product for Phase 1 testing. The product listed below was tested per the NFSI B101.1 Test Method for Measuring the Wet SCOF of Hard-Surface Walkways and the NFSI B101.3 Test Method for Measuring the Wet DCOF of Hard Surface Walkways on July 29, 2020.

Product Name	Average SCOF	Pass/Fail	Average DCOF	Pass/Fail
Carbinite Slip-Resistant Flooring	0.92	Pass	0.80	Pass

The product exceeded our minimum acceptable wet SCOF value of 0.60 and our minimum wet DCOF value of 0.45, therefore the product is eligible for Phase 2 Certification testing. Again, thank you for submitting your product to the NFSI.

Sincerely,

Russell J. Kendzior  
President



P.O. Box 92607  
Southlake, TX 76092  
www.nfsi.org  
Phone (817) 749-1700  
Email: info@nfsi.org

October 15, 2020

M. Sue Freyvogel  
Carbinite Metal Coatings  
463 Brownsdale Road, Unit 1  
Renfrew, PA 16053

Dear M. Sue Freyvogel:

Congratulations! The product submitted for Phase 2 Testing is now certified as providing "High-Traction".

Carbinite Slip-Resistant Flooring was tested on October 14, 2020 under the NFSI B101.1 Test Method for Measuring the Wet SCOF of Hard-Surface Walkways and the NFSI B101.3 Test Method for Measuring the Wet DCOF of Hard Surface Walkways. Our on-site examination revealed Static Coefficient of Friction (SCOF) values greater than a 0.60 and Dynamic Coefficient of Frictions (DCOF) values greater than 0.45; therefore, the product passed our Phase 2 level of certification for both SCOF and DCOF. Your certification is good through October 14, 2023.

An electronic version of the NFSI Certified logo may be obtained to which you are granted permission to attach to the product label, sales literature, website, etc.



Again, congratulations and thank you for submitting your product to the NFSI.

Sincerely,

Russell J. Kendzior  
President